



Sales & Services : Fire Extinguisher, Fire Alarm Work, Fire Hydrant, Yearly Maintenance, Industrial & Road Safety Equipment

223, Shalimar Trade Centre, 2nd Floor, Near Railway Station, Hamidia Road, Bhopal (M.P.)
 © agni_vijay@yahoo.com © www.agnivijay.com © 9993839448, 9926331175

CERTIFICATE OF FIRE EXTIGUISHER

M/S:- SCHOLAR'S PUBLIC HR. SECONDARY SCHOOL
 Address: GANJ BASODA (M.P.)

DATE: - 20-09-2022
 EXPIRY DATE: - 19-09-2023

This is certified M/S:-Agni Vijay, Has Following Refilling of fire extinguisher, has been Refilling by us as per relevant BIS specification on Refilling is warranted for a period of **ONE Year** from the date of Refilling on **Dated: 20/09/2022**

Sr. No.	Type of Fire Extinguisher	Capacity	Quantity
1)	Refilling OF ABC Power Stored Pressure Type Fire Extinguisher	2 K.G.	02 NOS
2)	Refilling OF ABC Power Stored Pressure Type Fire Extinguisher	5 K.G	01 NOS
3)	Refilling OF Co2 Gas Type Fire Extinguisher	4.5 K.G.	01 NOS

Further, we certify that the above material are made of best quality in workmanship free from all defects in material and workmanship, if any in consistency in the performances of the material in that event we undertake free repairs or replacement during the warrantee period. At your premises Refilling & servicing of fire extinguisher after New Refilling & servicing **Date:- 19/09/2023** after that in regarded.

Terms & Conditions -

1. Extinguisher should be operated by trained Person only.
2. Extinguisher should not be exposed directly to sunlight or any direct heat
3. Extinguisher should be maintained properly.
4. None operating or non functioning of extinguisher due to your negligence is not covered under this certificate.
5. Broken seal guarantee/ Warranty will end.
6. It is not the fire no-objection certificate

Authorized Signature

Agni Vijay
 Adam. Director - Business Development & Proprietor

